

PM 7

(773) 252 9453

Corrections for Permit Application #: 100294173
Address: 1613 S CENTRAL PARK AVE



Print Date: 7/2/09

22 - ARCHITECTURAL REVIEW

Correction
Natural light and ventilation [12]13-172-060] min. width of court & yards to be 3'-0" for height of 36'-0" & thereafter and additional 2" of width for each additional 1'-0" of height [12]13-172-130].
Master Bedroom removed and converted to den, see sheet A.4
Reviewer Comments: NEW MASTER BEDROOM.
Fire resistance--indicate construction and fire ratings for: columns, walls, beams, and ceilings 6[13-60-100]
Reviewer Comments: 1HR BASEMENT COLS. PROVIDE TYPICAL NEW PARTITION MATERIALS.
EXISTING COLUMNS TO BE WRAPPED IN 5/8" TYPE X DRYWALL, SEE SHEET A.4

Total # of Corrections = 2

25 - VENTILATION REVIEW

Correction
Information submitted is insufficient and/or incomplete for review. Additional corrections may be required. See comments.
Requested Date: 07/02/2009
Corrected Date: 07/02/2009
Reviewer Comments:
FURNACE EQUIPMENT 28 [13-184-020] : FURNACE data 28 [13-184-060] : NA
CORRECTION MADE, SEE SHEET M.1
Input in BTU's
FURNACE EQUIPMENT 28 [13-184-020] : Furnace data 28 [13-184-060] : NA
CORRECTION MADE, SEE SHEET M.1
Output in BTU's 28 [13-184-060B (1)].
CORRECTION MADE, SEE SHEET M.1
Reviewer Comments:
07/02/2009
Drawing Requirements: Provide all Recommended Ventilation Notes add details on drawing that are necessary to show compliance with all applicable code sections. [25-309]
CORRECTION MADE, SEE NEW SHEET M.2
Reviewer Comments:
07/02/2009
CHIMNEYS, FLUES, AND VENTS 28 [13-182-010] : Data (material, size, type, and location).
CORRECTION MADE, SEE SHEET M.1
Reviewer Comments: PLEASE SHOW HOW YOU ARE VENTING THE HOT WATER HEATER AND THE FURNACE. PLEASE CORRECT
07/02/2009

DCAP14 RD011309

Page 1 of 2

Department of Buildings - Permits
Richard J. Monoccholo, Commissioner



Print Date: 7/2/09

Corrections for Permit Application #: 100294173
Address: 1613 S CENTRAL PARK AVE

Total # of Corrections = 5

CITY OF CHICAGO
DEPARTMENT OF BUILDINGS
Certified Corrections Program
Professionals of Record Certification Statement

All licensed professionals that stamp the plans and make the Department of Buildings' requested code corrections must sign and seal this Certification.

Application Number: 100294173

Project Address: 1613 S. CENTRAL PARK

Chicago, IL 606 23

I hereby certify that I am the Professional of Record for this Project and to the best of my knowledge, I have personally made all requested code corrections to the plans sets as reflected on the attached correction sheet.

ARCHITECT
Signature: *Diana Konstantinov*

Printed Name: DIANA KONSTANTINOV

Address: 419 HARVEY ST., OAK PARK

Dated: 07/14/2009




STRUCTURAL ENGINEER:
Signature: _____

Printed Name: _____

Address: _____

Dated: _____



PLUMBING CONSULTANT:
(PROFESSIONAL ENGINEER)
Signature: _____

Printed Name: _____

Address: _____

Dated: _____



Richard M. Daley, Mayor
City of Chicago



196448-19-6-1107



419-C Harrison Street
Oak Park, IL 60304
Tel: (708) 948-7332
Fax: (708) 575-3004
@: us@kbpartnership.com

PROJECT NAME:
PROPOSED GARDEN UNIT

PROJECT ADDRESS:
1613 S. Central Park Av.
Chicago, IL 60623

SHEET TITLE:
CERTIFIED
CORRECTION

REVISIONS:

ISSUED FOR PERMIT:
5-07-2009

This drawing is the sole property of KBP, Inc., and is protected under US Copyright law and the Architectural Works Protection Act of 1990. The copy of this drawing and/or distribution to unauthorized personnel or construction of the structure depicted herein without express written consent of KBP, Inc., would constitute infringement of KBP, Inc. The recipient of this drawing acknowledges and agrees that the ownership of the drawing and all other rights, title, and interest therein, including without limitation, all rights under US Copyright and other intellectual property law, are retained by KBP, Inc.

COPYRIGHT © 2009
ALL RIGHTS RESERVED

SHEET NUMBER:

CC